

ADDENDUM NO. 2

October 3, 2019

Attention All Bidders and Plan Holders:

Sand Sheds Construction Project
FEMA Project No. DR 4309 PW 238
County Project No. 90-17F509100443B

The following shall be changed in the Contract:

For all Three Sand Sheds:

The Engineered drawings for the cast-in place concrete walls call out 5 sack concrete mix which will be changed to 4000 psi air-entrained concrete.

All bidders will be required to furnish evidence of the receipt of this addendum on the Proposal Signature page. This addendum will be incorporated in and made a part of the contract when awarded, and when formally executed.

**END OF
ADDENDUM NO. 2**